

Manufactured articles, materials and equipment shall be applied, installed, connected, erected, used, cleaned and conditioned as directed by the respective manufacturers unless directed otherwise by the provisions of these Specifications.

3.0 SUBMITTALS

Provide at least four copies of each submittal, and allow two weeks for Engineer's review. Such submittals are to be approved by Engineer prior to incorporation of any materials into the work.

4.0 WARRANTIES

Meters should have a 10 year full plus 10 year prorated warranty, including any batteries. It is preferred that meter warranties start upon delivery to the project site.

Meter transmitters should have a 10 year full plus 10 year prorated warranty, including any batteries. The warranty shall include repair or replacement without cost to the Owner of any component of the system failing as a result of manufacturer's defect during the warranty period.

All handheld and mobile reading equipment (i.e. Toughbook laptop or tablet) included with the Automated Reading System shall include an original manufacturer's warranty, along with a hardware service contract on all hardware components of the system from delivery through **December 31, 2025**. Software supplied with the system shall be updated and maintained by the manufacturer guaranteed for compatibility with all other components of the system through **December 31, 2025**.

The warranty shall include repair or replacement without cost to the Owner of any component of the system failing as a result of manufacturer's defect during the warranty period.

END OF SECTION 02-201

PARTIAL
PREVIEW