

Todd County Water District
Novelis Water Supply Project
Contract No. 2 –Tank Addition

ADDENDUM No. 2

January 28, 2019

This ADDENDUM to plans, specifications and bidding documents for the subject project modifies the referenced items to the extent described herein. Items not modified by this ADDENDUM remain unchanged and in full effect. Bidders are required to acknowledge receipt of this ADDENDUM on the Bid Form.

1. Technical Specifications: Section 11-102 “Composite Elevated Welded Steel Water Storage Tank” (Attachments: none):

Replace Paragraph 2.1.H “Foundation” as follows:

- H. Foundation: shall be designed by the tank manufacturer and design drawings shall be submitted to the Owner as stated above.
 - 1. Excavation shall be in accordance with Division 02 of these Specifications.
 - 2. Concrete work shall be in accordance with Division 03 of these Specifications and other requirements set forth in this Section.
 - 3. Piping and valves shall be in accordance with Section 11-200 of these Specifications.
 - 4. Tank foundation is to be designed as a pile-type deep foundation utilizing the reinforced cast-in-place drilled concrete shaft method. The piling foundation system shall be designed in accordance with the loadings imposed by the supported structure in accordance with parameters set forth in the project geotechnical report. Pilings shall transfer all of the vertical load from the supported structure to sound bedrock.

END OF ADDENDUM NO. 2 TEXT
This ADDENDUM consists of a total of 1 page.